CLIENT INFORMANTION		
Name: Berlin Central School District		
Address: 17400 Route 22, Cherry Plain, NY 12040		
Client Rep: Cyril Grant (518) 658-1500, Option 8, Ext. 3011		
SCHOOL/PROJECT INFORMATION		
BLDG NO./NAME: Berlin Elementary School		
BLDG ADDRESS: 53 School Street, Berlin, NY 12022		
CONTACT NAME & NUMBERS:	Cyril Grant (518) 658-1500, Option 8,	
(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:

SAMPLE DATA

Sample Description ID (ID must match container label)

Lab Sample #	BOCES Sample #	Location
1	BES-01-CF-P-01	118
2	BES-01-DW-P-02	118 Corridor
3	BES-01-DW-P-03	118 Corridor
4	BES-01-CF-P-04	112
5	BES-01-DW-P-05	112
6	BES-01-CF-P-06	111
7	BES-01-DW-P-07	111
8	BES-01-BF-P-08	Nurse's Office Bathroom
9	BES-01-DW-P-09	Girls Restroom - Corridor
10	BES-01-DW-P-10	Girls Restroom - Corridor
11	BES-01-DW-P-11	Cafeteria Corridor
12	BES-01-DW-P-12	Cafeteria Corridor
13	BES-01-KF-P-13	Kitchen Sink - Left
14	BES-01-KF-P-14	Kitchen Sink - Right
15	BES-01-KF-P-15	Kitchen - Handwashing
16	BES-01-CF-P-16	107
17	BES-01-CF-P-17	108
18	BES-02-DW-P-18	Girl's Restroom Corridor
19	BES-02-DW-P-19	Girl's Restroom Corridor
20	BES-02-DW-P-20	Boy's Restroom Corridor
21	BES-02-DW-P-21	Boy's Restroom Corridor

			Date of Sampling: 5/22/2025
			Samples Taken By: Tim LeVan
			District Staff: Cyril Grant

, Ext. 3011

(4) Yr 1st Mod:	(5) Yr. 2nd Mod:

Outlet Information

Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Results from 5/22/2025 ug/L
Classroom Sink Faucet			**X**	**2.4**
Water Fountain			**X**	**<1.0**
Bottle Filler			**X**	**<1.0**
Classroom Sink Faucet			**X**	**7.6**
Sink Bubbler			**X**	**3.4**
Classroom Sink Faucet			**X**	**2.3**
Sink Bubbler			**X**	**1.4**
Bathroom Faucet			**X**	**4.3**
Water Fountain			**X**	**<1.0**
Bottle Filler			**X**	**<1.0**
Water Fountain			**X**	**<1.0**
Bottle Filler			**X**	**<1.0**
Sink Faucet			**X**	**5.6**
Sink Faucet			**X**	**4.7**
Sink Faucet			**X**	**2.6**
Classroom Sink Faucet			**X**	**14.2**
Classroom Sink Faucet			**X**	**10.6**
Water Fountain			**X**	**Not working No test**
Bottle Filler			**X**	**Not working No test**
Water Fountain			**X**	**<1.0**
Bottle Filler			**X**	**<1.0**

Results from ug/L	Results from ug/L	Remediation

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved		
CHAIN OF CUSTODY		
Relinquished By:		
INSTRUCTIONS TO THE LABORATORY - Analize all samples for lead		
Lab:	PACE Analytical	
Contact:		
Comments: Provide Laboratory Data Report (LDR) and Chain of Custody		

l w/HNO3@ pH by lab				
Received By:			**Time:**	**Date:**