



January 22, 2026

Cyril Grant  
Berlin Central School District  
17400 State Route 22  
Cherry Plain, NY 12040

RE: Project: BERLIN ELEMENTARY SCHOOL 1/15  
Pace Project No.: 70402094

Dear Cyril Grant:

Enclosed are the analytical results for sample(s) received by the laboratory on January 15, 2026. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Alexandria Correa  
alexandria.correa@pacelabs.com  
516-370-6000  
Project Manager

Enclosures

cc: Tracey Catalfamo, Questar BOCES  
Tim Levan, Questar BOCES  
Colleen Mills, Berlin Central School District



## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



## CERTIFICATIONS

Project: BERLIN ELEMENTARY SCHOOL 1/15

Pace Project No.: 70402094

---

### **Pace Analytical Services, LLC - Melville, NY**

575 Broad Hollow Rd, Melville, NY 11747

Connecticut Certification #: PH-0435

Delaware Certification # NY 10478

Maryland Certification #: 208

Massachusetts Certification #: M-NY026

New Hampshire Certification #: 2987

New Jersey Certification #: NY158

New York Certification #: 10478 Primary Accrediting Body

Pennsylvania Certification #: 68-00350

Rhode Island Certification #: LAO00340

Texas Certification #: T104704582

Florida Certification #: E871198

---

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: BERLIN ELEMENTARY SCHOOL 1/15

Pace Project No.: 70402094

Sample: BES-01-CF-P-01		Lab ID: 70402094001	Collected: 01/14/26 05:30	Received: 01/15/26 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>2.9</b>	ug/L	1.0	1		01/21/26 13:02	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: BERLIN ELEMENTARY SCHOOL 1/15

Pace Project No.: 70402094

Sample: BES-01-DW-P-02		Lab ID: 70402094002	Collected: 01/14/26 05:28	Received: 01/15/26 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		01/21/26 13:03	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: BERLIN ELEMENTARY SCHOOL 1/15

Pace Project No.: 70402094

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: BES-01-DW-P-03</b>								
<b>Lab ID: 70402094003</b>								
Collected: 01/14/26 05:28								
Received: 01/15/26 06:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/21/26 13:04	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: BERLIN ELEMENTARY SCHOOL 1/15

Pace Project No.: 70402094

Sample: BES-01-DW-P-05		Lab ID: 70402094004	Collected: 01/14/26 05:24	Received: 01/15/26 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>2.0</b>	ug/L	1.0	1		01/21/26 13:06	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: BERLIN ELEMENTARY SCHOOL 1/15

Pace Project No.: 70402094

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: BES-01-CF-P-06</b>								
<b>Lab ID: 70402094005</b>								
Collected: 01/14/26 05:22								
Received: 01/15/26 06:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<b>2.3</b>	ug/L	1.0	1		01/21/26 13:07	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: BERLIN ELEMENTARY SCHOOL 1/15

Pace Project No.: 70402094

Sample: BES-01-DW-P-07		Lab ID: 70402094006	Collected: 01/14/26 05:22	Received: 01/15/26 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>1.8</b>	ug/L	1.0	1		01/21/26 13:08	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: BERLIN ELEMENTARY SCHOOL 1/15

Pace Project No.: 70402094

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: BES-01-BF-P-08</b>								
<b>Lab ID: 70402094007</b>								
Collected: 01/14/26 05:19								
Received: 01/15/26 06:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	3.2	ug/L	1.0	1		01/21/26 13:09	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: BERLIN ELEMENTARY SCHOOL 1/15

Pace Project No.: 70402094

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: BES-01-DW-P-09</b>								
<b>Lab ID: 70402094008</b>								
Collected: 01/14/26 05:17								
Received: 01/15/26 06:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/21/26 13:13	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: BERLIN ELEMENTARY SCHOOL 1/15

Pace Project No.: 70402094

Sample: BES-01-DW-P-10		Lab ID: 70402094009	Collected: 01/14/26 05:17	Received: 01/15/26 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/21/26 13:14	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: BERLIN ELEMENTARY SCHOOL 1/15

Pace Project No.: 70402094

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: BES-01-DW-P-11</b>								
<b>Lab ID: 70402094010</b>								
Collected: 01/14/26 05:14								
Received: 01/15/26 06:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/21/26 13:16	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: BERLIN ELEMENTARY SCHOOL 1/15

Pace Project No.: 70402094

Sample: BES-01-DW-P-12		Lab ID: 70402094011	Collected: 01/14/26 05:14	Received: 01/15/26 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/21/26 13:17	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: BERLIN ELEMENTARY SCHOOL 1/15

Pace Project No.: 70402094

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: BES-01-KF-P-14</b>								
<b>Lab ID: 70402094012</b>								
Collected: 01/14/26 05:11								
Received: 01/15/26 06:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	1.1	ug/L	1.0	1		01/21/26 13:18	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: BERLIN ELEMENTARY SCHOOL 1/15

Pace Project No.: 70402094

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: BES-01-KF-P-15</b>								
<b>Lab ID: 70402094013</b>								
Collected: 01/14/26 05:12								
Received: 01/15/26 06:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<b>10.6</b>	ug/L	1.0	1		01/21/26 13:20	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: BERLIN ELEMENTARY SCHOOL 1/15

Pace Project No.: 70402094

Sample: BES-02-DW-P-18		Lab ID: 70402094014	Collected: 01/14/26 05:37	Received: 01/15/26 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/21/26 13:23	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: BERLIN ELEMENTARY SCHOOL 1/15

Pace Project No.: 70402094

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: BES-02-DW-P-19</b>								
<b>Lab ID: 70402094015</b>								
Collected: 01/14/26 05:37								
Received: 01/15/26 06:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/21/26 13:29	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: BERLIN ELEMENTARY SCHOOL 1/15

Pace Project No.: 70402094

Sample: BES-02-DW-P-20		Lab ID: 70402094016	Collected: 01/14/26 05:36	Received: 01/15/26 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/21/26 13:33	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: BERLIN ELEMENTARY SCHOOL 1/15

Pace Project No.: 70402094

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: BES-02-DW-P-21</b>								
<b>Lab ID: 70402094017</b>								
Collected: 01/14/26 05:36								
Received: 01/15/26 06:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/21/26 13:34	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



**QUALITY CONTROL DATA**

Project: BERLIN ELEMENTARY SCHOOL 1/15

Pace Project No.: 70402094

QC Batch:	437410	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70402094001, 70402094002, 70402094003, 70402094004, 70402094005, 70402094006, 70402094007, 70402094008, 70402094009, 70402094010, 70402094011, 70402094012, 70402094013		

METHOD BLANK:	2347038	Matrix:	Water
Associated Lab Samples:	70402094001, 70402094002, 70402094003, 70402094004, 70402094005, 70402094006, 70402094007, 70402094008, 70402094009, 70402094010, 70402094011, 70402094012, 70402094013		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	01/21/26 12:43	

LABORATORY CONTROL SAMPLE: 2347039							
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers	
Lead	ug/L	50	49.6	99	85-115		

MATRIX SPIKE SAMPLE: 2347041							
Parameter	Units	70402193001 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	63.1	126	70-130	

MATRIX SPIKE SAMPLE: 2347043							
Parameter	Units	70402193002 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	54.3	108	70-130	

SAMPLE DUPLICATE: 2347040							
Parameter	Units	70402193001 Result	Dup Result	RPD	Qualifiers		
Lead	ug/L	<1.0	<1.0				

SAMPLE DUPLICATE: 2347042							
Parameter	Units	70402193002 Result	Dup Result	RPD	Qualifiers		
Lead	ug/L	<1.0	<1.0				

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



**QUALITY CONTROL DATA**

Project: BERLIN ELEMENTARY SCHOOL 1/15

Pace Project No.: 70402094

QC Batch: 437411 Analysis Method: EPA 200.8  
 QC Batch Method: EPA 200.8 Analysis Description: 200.8 MET No Prep Drinking Water  
 Laboratory: Pace Analytical Services - Melville  
 Associated Lab Samples: 70402094014, 70402094015, 70402094016, 70402094017

METHOD BLANK: 2347045 Matrix: Water  
 Associated Lab Samples: 70402094014, 70402094015, 70402094016, 70402094017

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	01/21/26 13:21	

LABORATORY CONTROL SAMPLE: 2347046

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	49.3	99	85-115	

MATRIX SPIKE SAMPLE: 2347048

Parameter	Units	70402094014 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	49.0	98	70-130	

MATRIX SPIKE SAMPLE: 2347050

Parameter	Units	70402094015 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	49.7	99	70-130	

SAMPLE DUPLICATE: 2347047

Parameter	Units	70402094014 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

SAMPLE DUPLICATE: 2347049

Parameter	Units	70402094015 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



## QUALIFIERS

Project: BERLIN ELEMENTARY SCHOOL 1/15

Pace Project No.: 70402094

---

### DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



**QUALITY CONTROL DATA CROSS REFERENCE TABLE**

Project: BERLIN ELEMENTARY SCHOOL 1/15  
 Pace Project No.: 70402094

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70402094001	BES-01-CF-P-01	EPA 200.8	437410		
70402094002	BES-01-DW-P-02	EPA 200.8	437410		
70402094003	BES-01-DW-P-03	EPA 200.8	437410		
70402094004	BES-01-DW-P-05	EPA 200.8	437410		
70402094005	BES-01-CF-P-06	EPA 200.8	437410		
70402094006	BES-01-DW-P-07	EPA 200.8	437410		
70402094007	BES-01-BF-P-08	EPA 200.8	437410		
70402094008	BES-01-DW-P-09	EPA 200.8	437410		
70402094009	BES-01-DW-P-10	EPA 200.8	437410		
70402094010	BES-01-DW-P-11	EPA 200.8	437410		
70402094011	BES-01-DW-P-12	EPA 200.8	437410		
70402094012	BES-01-KF-P-14	EPA 200.8	437410		
70402094013	BES-01-KF-P-15	EPA 200.8	437410		
70402094014	BES-02-DW-P-18	EPA 200.8	437411		
70402094015	BES-02-DW-P-19	EPA 200.8	437411		
70402094016	BES-02-DW-P-20	EPA 200.8	437411		
70402094017	BES-02-DW-P-21	EPA 200.8	437411		

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.

WO#: 70402094



POTABLE WATER SAMPLING FOR LEAD CONCENTRATION SAMPLE COLLECTION FORM  
Appendix D

Page 1/14

Date of Sampling: 1/14  
 Samples Taken By: Craig Hansen  
 District Staff: Daryl Maxon

CLIENT INFORMATION  
 Name: Berlin Central School District  
 Address: 17400 Route 22, Cherry Plain, NY 12040  
 Client Rep: Cyril Grant (518) 658-1500, Option 8, Ext. 3011  
 SCHOOL/PROJECT INFORMATION  
 BLDG NO./NAME: Berlin Elementary School  
 BLDG ADDRESS: 53 School Street, Berlin, NY 12022  
 CONTACT NAME & NUMBERS: Cyril Grant (518) 658-1500, Option 8, Ext. 3011

(1) Yr. Built: (2) Yr. 1st Add: (3) Yr 2nd Add: (4) Yr 1st Mod: (5) Yr. 2nd Mod:

SAMPLE DATA

Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	30 Second Flush Draw	Time of Collection (24hr)	Service Connection Draw	Time of Collection (24hr)	Water Main Draw	Time of Collection (24hr)
1	BES-01-CF-P-01	118	Classroom Sink Faucet			X	5:30						
2	BES-01-DW-P-02	118 Corridor	Water Fountain			X	5:28						
3	BES-01-DW-P-03	118 Corridor	Bottle Filler			X	5:28						
5	BES-01-DW-P-05	112	Sink Bubbler			X	5:24						
6	BES-01-CF-P-06	111	Classroom Sink Faucet			X	5:22						
7	BES-01-DW-P-07	111	Sink Bubbler			X	5:22						
8	BES-01-BF-P-08	Nurse's Office Bathroom	Bathroom Faucet			X	5:19						
9	BES-01-DW-P-09	Girls Restroom - Corridor	Water Fountain			X	5:17						
10	BES-01-DW-P-10	Girls Restroom - Corridor	Bottle Filler			X	5:17						
11	BES-01-DW-P-11	Cafeteria Corridor	Water Fountain			X	5:14						
12	BES-01-DW-P-12	Cafeteria Corridor	Bottle Filler			X	5:14						
14	BES-01-KF-P-14	Kitchen Sink - Right	Sink Faucet			X	5:11						
15	BES-01-KF-P-15	Kitchen - Handwashing	Sink Faucet			X	5:12						
18	BES-02-DW-P-18	Girls Restroom Corridor	Water Fountain			X	5:37						
19	BES-02-DW-P-19	Girls Restroom Corridor	Bottle Filler			X	5:37						
20	BES-02-DW-P-20	Boy's Restroom Corridor	Water Fountain			X	5:36						
21	BES-02-DW-P-21	Boy's Restroom Corridor	Bottle Filler			X	5:36						

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3 @ pH by lab

CHAIN OF CUSTODY

Relinquished By: *[Signature]* Received By: *[Signature]* Date: 1/14  
 Time: 2:50  
 INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead  
 Lab: PACE Analytical  
 Comments: Provide Laboratory Data Report (LDR) and Chain of Custody

UND PUF  
1/15/26 603

*Paul M...* 1/15/26



**WO#: 70402094**

Client Name: **BERLINCSO**

Project #

PM: ALC Due Date: 01/29/26  
 CLIENT: BERLINCSO

Courier:  Fed Ex  UPS  USPS  Client  Commercial  Pace  Other

Tracking #:

Custody Seal on Cooler/Box Present:  Yes  No Seals intact:  Yes  No Temperature Blank Present:  Yes  No  
 Packing Material:  Bubble Wrap  Bubble Bags  Ziploc  None  Other Type of Ice: Wet Blue None

Thermometer Used: M20 Correction Factor: 0.1  Samples on ice, cooling process has begun  
 Cooler Temperature (°C): 0.9 Cooler Temperature Corrected (°C): 1.0 Date/Time 5035A kits placed in freezer \_\_\_\_\_

Temp should be above freezing to 6°C

USDA Regulated Soil  N/A, water sample)

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)?  Yes  No

Did samples originate from a foreign source including Hawaii and Puerto Rico)?  Yes  No

If Yes to either question, fill out a Regulated Soil Checklist (ENV-FRM-MELV-0076) and include with SCUR/COC paperwork.

Date and Initials of person examining contents: MS/26 CT

	COMMENTS:
Chain of Custody Present: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	1.
Chain of Custody Filled Out: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	2.
Chain of Custody Relinquished: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	3.
Sampler Name & Signature on COC: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	5.
Short Hold Time Analysis (<72hr): <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	6.
Rush Turn Around Time Requested: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	7.
Sufficient Volume: (Triple volume provided for MS/MSD) <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	8.
Correct Containers Used: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	9.
-Pace Containers Used: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	10.
Containers Intact: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	10.
Filtered volume received for Dissolved tests <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	11. Note: if sediment is visible in the dissolved container.
Sample Labels match COC: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	12.
-Includes date/time/ID/Analysis Matrix: SL <u>WT</u> OIL OTHER	

Date and Initials of person checking preservation: MS/26 CT

All containers needing preservation have been <u>MS/26</u> <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	13. <input type="checkbox"/> HNO <sub>3</sub> <input type="checkbox"/> H <sub>2</sub> SO <sub>4</sub> <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
pH paper Lot #	Sample #
All containers needing preservation are found to be in compliance with method recommendation? (HNO <sub>3</sub> , H <sub>2</sub> SO <sub>4</sub> , HCl, NaOH>9 Sulfide, <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A NAOH>12 Cyanide)	
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water).	
Per Method, VOA pH is checked after analysis	Initial when completed: Lot # of added preservative: Date/Time preservative added:
Samples checked for dechlorination: <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	14.
KI starch test strips Lot #	Positive for Res. Chlorine? Y N
Residual chlorine strips Lot #	15. Positive for Sulfide? Y N
SM 4500 CN samples checked for sulf <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	16.
Lead Acetate Strips Lot #	17.
Headspace in ALK Bottle (>6mm): <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Headspace in VOA Vials (>6mm): <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Trip Blank Present: <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Trip Blank Custody Seals Present <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	

Client Notification/ Resolution:

Field Data Required? Y / N

Person Contacted:

Date/Time:

Comments/ Resolution:

\* PM (Project Manager) review (which includes the SCUR) is documented electronically in LIMS.